

BAC RESOLUTION RECOMMENDING AWARD FOR THE PROJECT, PROCUREMENT OF CALCIUM HYPOCHLORITE AND CHLORINE DIOXIDE LIQUID FOR SMWD'S REQUIREMENTS FOR CY 2021

BAC RESOLUTION NO. 2021-009

- WHEREAS, the Santa Maria Water District BAC initiated bidding for the above stated project. The BAC secretariat has published in PhilGeps and SMWD's website an invitation to Bid for the period, December 11 to 18, 2020. The same invitation was sent to three (3) observers and was also posted at conspicuous premise of the Santa Maria Water District's office on the same period;
- WHEREAS, in response to the said invitation, only one supplier of chemical responded to the ITB or Invitation to Bid. The company was **Chemical Research Products Industrial Sales Inc.** or **CHEMRES**, a company well known and a recognized supplier of high quality Calcium Hypochlorite. It purchased bidding documents and submitted the same on December 29, 2020 at 10:45 AM, which was six (6) days prior to bid submission and opening on January 4, 2021;
- WHEREAS, no other bidder submitted bidding documents till the scheduled bid opening for the project, the BAC pushed thru with the bid opening at exactly 1:00 PM, January 4, 2021. The representative of the bidder were present namely, Ms. Marissa Directo and Joyce Royales;
- WHEREAS, the SMWD BAC upon thorough evaluation and examination of all the eligibility and technical documents declared Chemical Research Products Industrial Sales, Inc. as eligible bidder. The bidding documents of the eligible bidder, was opened and passed the preliminary examination of bids;

Name of Bidder	Bid Amount (As Read)	% Variance from ABC
Chemical Research Products Industrial Sales, Inc.	P 2,351,000.00	0.015%
nothing follows		

WHEREAS, Bid Evaluation was made on January 5, 2021 on the bid submitted by the bidder and found no discrepancy on the detailed bids against the total bid amount:

Name of Bidder	Bid Amount (As Calculated)	% Variance from ABC
Chemical Research Products Industrial Sales, Inc.	P 2,351,000.00	0.015%
nothing follows		

WHEREAS, post-qualification was conducted on January 7, 2021 by Engr. Mac Daniel Alejandro., BAC Member-End User and BAC Secretariat, Charito S. Fernando. The sample of calcium hypochlorite was brought at PIPAC Laboratory for testing, unfortunately the result was unfavorable, the chlorine is only sixty four percent (64%), the chlorine content required is seventy percent (70%);

WHEREAS, on January 29, 2021, another chlorine sample was brought again at PIPAC Laboratory for testing, the sample came from the latest batch of chlorine available in the bidder's warehouse.

TÚVRhe

Management System ISO 9001:2015

"YOUR WATER OUR OBLIGATION YOUR CONVENIENCE, OUR SERVICE"



The result of the test was forwarded to the SMWD BAC on February 8, 2021 whereby the result is seventy percent (70%) compliant to the technical specification of the SMWD on chemical analysis;

WHEREAS, it was ascertained that the company, CHEMICAL RESEARCH PRODUCTS INDUSTRIAL SALES, INC., was capable financially, technically, and legally to implement the project, PROCUREMENT OF CALCIUM HYPOCHLORITE AND CHLORINE LIQUID FOR SMWD'S REQUIREMENTS FOR CY 2021);

NOW, THEREFORE, We, the Members of the Bids and Awards Committee, hereby RESOLVED as it is hereby RESOLVED:

- a) To declare CHEMICAL RESEARCH PRODUCTS INDUSTRIAL SALES, INC., with office address at No. 1606-A East Tower, Philippine Stock Exchange Center, Exchange Road, Ortigas Center, Pasig City as the Bidder who is the Single Calculated and Responsive Bid for the project, "Procurement of Calcium Hypochlorite and Chlorine Dioxide Liquid for SMWD's Requirements for CY 2021. And to recommend the contract award in the amount of **Two Million Three Hundred Fifty One Thousand** Pesos (P 2,351,000.00).
- b) To recommend for approval by the General Manager of the Santa Maria Water District the foregoing findings.

RESOLVED, at the Santa Maria Water District's Office, Santa Maria, Bulacan, this 8th day of February 2021.

Maria Leonora S. Romarate **BAC Chairman**

Engr. Gerson L. Francisc **BAC** Member

Engr. Edgardo E. Dela Torre Jr.

BAC Member

Engr. Mac Daniel Alejandro

Mary Diana(\$. dela Cruz, CPA

BAC Member

Approved by:

Engr. Carlos N. Santos, Jr.

General Manager

Date approved:

