

September 28, 2021

P-RFQ No. 2021-055

REQUEST FOR QUOTATION

SUPPLY AND DELIVERY OF HDPE AND VARIOUS PLASTIC FITTINGS

The Santa Maria Water District (SMWD) hereinafter referred to as "the Purchaser", through its Bids and Awards Committee (BAC), invite interested parties to submit price quotation for the project, **"SUPPLY AND DELIVERY OF HDPE AND VARIOUS PLASTIC FITTINGS"** through Small Value Procurement (Sec. 53.9 of R.A. No. 9184) with Approved Budget for the Contract (ABC) of Seven Hundred Fifty One Thousand Two Hundred Thirty and Fifty Seven Centavos Only (**P 751,230.57**).

	Description	Qty	Unit	Unit Cost	Total Amount
1	UPVC UNION COUPLING 1	60	pc		
2	UPVC UNION COUPLING 1/2	635	pc		
3	HDPE TUBING 1 SDR 11 (BLUE)	388	mtr		
4	PLASTIC ADAPTOR 1	208	pc		
5	PLASTIC ADAPTOR 1/2	3,590	pc		
6	PLASTIC ELBOW 1 X 90 (32mm)	14	pc		
7	PLASTIC ELBOW 1/2 X 90 (20mm)	66	pc		
8	PLASTIC ELBOW 3/4 X 90	1	pc		
9	PLASTIC SADDLE CLAMP 3 X 1 w/ tapping ferrule	118	set		
10	PLASTIC SADDLE CLAMP 4 X 1 w/ tapping ferrule	115	set		
11	PLASTIC SADDLE CLAMP 6 X 1 w/ tapping ferrule	43	set		
	Note: This is a one-lot project				
	nothing follows				



All items listed under the purchaser's specifications must be complied on a pass-fail basis.

Failure to meet any one of the requirements will result to rejection. Likewise, it is understood that Purchaser's specifications are minimum requirements. The Bidder/Supplier may offer higher specifications or additional items, if any.

Procurement procedures will be conducted in accordance with the provisions of the Implementing Rules and Regulations (IRR) of Republic Act No. 9184 (Government Procurement Reform Act).

It is the intent of the Purchaser to evaluate the quotation for the item and award will be made to the quotation resulting in the overall lowest cost. Contract Award will be made to the lowest evaluated quotation meeting purchaser's technical specifications.

Likewise, in accordance with Section 54.6 and Appendix A of Annex "H" (Consolidated Guidelines for the Alternative Methods of Procurement) of the IRR of RA No. 9184, the supplier shall provide the following documentary requirements as a **condition for award** of the contract:

1. PhilGEPS Registration Number; and
2. Mayor's/Business Permit.
3. Photo Copy of Sample Official Receipt (OR)
4. Certificate of Registration (BIR FORM 2303)
5. Duly Notarized Omnibus Sworn Statement.
6. income Business Tax Return

Your prices must be quoted in Philippine Peso and must include the unit price and total price, inclusive of all taxes to be paid and other incidental cost to the delivery site if the contract is awarded.

All quotations may be typewritten or handwritten and may be placed in sealed envelope marked **"SUPPLY AND DELIVERY OF HDPE AND VARIOUS PLASTIC FITTINGS"** (RFQ No. 2021-056) and must be submitted on or before **October 4, 2021, 11:00AM** at the SMWD main office. It may also be sent thru email on our official email address at smwdbulacan@yahoo.com on the specified time stated above and address to the General Manager, Engr. Carlos N. Santos Jr.

Quotations shall be valid for thirty (30) calendar days from the deadline of submission of the same.

The delivery period shall be within **5 Days** from receipt of the Purchase Order (PO). The supplier should inform the purchaser at least two (2) days before the date of delivery. The Purchaser shall have the right to reject or to return the items that will be declared defective. The delivery will be made only during working days from 8:00 AM to 5:00 PM.

DELIVERY SITE: General Services Division of SMWD located at J. P. Rizal St., Dulong Bayan, Santa Maria, Bulacan.



Santa Maria WATER DISTRICT

The prospective supplier shall submit the following:

- a) Duly accomplished Quotation Form (*Attachment A*); and
- b) Brochures of the items offered, if any.

The Santa Maria Water District reserves the right to accept or reject any quotation, and to annul the procurement process and reject all quotations at any time prior to Contract award, without thereby incurring any liability to the affected supplier or suppliers. SMWD also reserves the right to waive any required formality in the proposals received, and select the proposal which it determines to be the most advantageous to the government.

Prepared by:

 9-27-2021
Romel P. Lazaga
Procurement Assistant

Noted by:

 9-27-2021
Maria Leonora S. Romarate
BAC Chairperson

SPECIFICATIONS OF HDPE TUBING AND PLASTIC FITTINGS:								
PARTICULARS	SPECIFICATIONS	STATEMENT OF COMPLIANCE						
HDPE Tubing 1, SDR 11 Blue	<p>a. Material – the extrusion compound shall either be Grade P33, Class C or Grade P34, Class C (PE3306 or PE3406) as defined by ASTM D1248</p> <p>b. Dimensions – Standard Dimension Ratio (SDR) shall be as follows:</p> <table><tr><th>Outside Size Nominal</th><th>Dia.</th></tr><tr><th>(mm) (in)</th><th>Pressure Thickness</th></tr><tr><td>32mm</td><td>1" PN for $\delta_s= 8$ Mpa 3.0</td></tr></table> <p>Standard – Conforming to ISO 161/1/ISO 3607 Series, SDR PR based on controlled Outside Diameter</p> <p>Markings – shall be clearly marked at intervals of not more than 0.6 M with nominal size, type of (PE 3306, OR PE 3406). Standard Dimension Ration (SDR 11), manufacturer's trade name and production code, and the seal of approval from an accredited testing laboratory.</p> <p>c. Joint method – Compression Fittings, Mechanical Jointing.</p> <p>d. Joint method – Compression Fittings, Mechanical Jointing.</p> <p>e. PNS 65 ; 20 mm Ø Threaded</p>	Outside Size Nominal	Dia.	(mm) (in)	Pressure Thickness	32mm	1" PN for $\delta_s= 8$ Mpa 3.0	
Outside Size Nominal	Dia.							
(mm) (in)	Pressure Thickness							
32mm	1" PN for $\delta_s= 8$ Mpa 3.0							
Plastic Adaptor, Plastic Union Coupling, & Plastic Elbow	<p>01 Materials are high grade polypropylene</p> <p>02 Dimension conforms to ISO standards.</p> <p>03 Rubber gasket/O-ring shall be made from nitrile rubber conforming to ISO 4633, suitable for potable and chlorinated water.</p> <p>04 Clinching Ring is made of acetal co-polymer conforming to ISO 14236.</p> <p>05 Holder and Locking Nut are made of Polypropylene</p> <p>06 Fitting color shall be black.</p> <p>07 No loose component.</p> <p>08 Markings: Manufacturer's Name/Trademark/Trademark, size</p> <p>09 Working Pressure is 230 PSI</p>							
Saddle Clamp 3 x 1 (Plastic) Saddle Clamp 4 x 1 (Plastic) Saddle Clamp 6 x 1 (Plastic)	<p>01 Materials is high grade polypropylene</p> <p>02 Dimension conforms to ISO standards.</p> <p>03 Material of bolt and nuts shall be stainless steel</p> <p>04 Clinching Ring is made of acetal co-polymer conforming to ISO 14236.</p> <p>05 Rubber gasket/O-ring shall be made from nitrile rubber conforming to ISO 4633, suitable for potable and chlorinated water.</p> <p>06 Thrust Ring is made from Nylon.</p> <p>07 Compression joint shall conform to ISO 3501 as per ISO 14236.</p> <p>08 Fitting color shall be black.</p> <p>09 No loose component.</p> <p>10 Markings: Manufacturer's Name/Trademark/Trademark, size PP maybe in the form of sticker or paint.</p> <p>11 All plastic saddle clamps are with Tapping Ferrule</p>							



Santa Maria

WATER DISTRICT

"YOUR WATER. OUR OBLIGATION
YOUR CONVENIENCE. OUR SERVICE."



Management
System
ISO 9001:2015
www.tuv.com
ID: 9108645560