

**SUPPLEMENTAL/ BID BULLETIN**  
**SBB2025-006**

**For the Project:**  
**SUPPLY DELIVERY, INSTALLATION, AND COMMISIONING OF A WATER FILTER SYSTEM IN**  
**PUMP STATION NO. 5**  
**Reference No. SMWD-PB2025-G-06-007**

This supplemental/Bid Bulletin is issued to all prospective bidders to provide a clarification regarding various aspects of the bidding documents as discussed during the Pre-bid Conference held on June 13, 2025 at 10:40 A.M for the project mentioned above.

The amendments made on the bidding documents shall constitute an integral component of the bidding process.

**REVISION NO. 1 – SCHEDULE OF REQUIREMENTS**

The delivery schedule expressed as weeks/months stipulates hereafter a delivery date which is the date of delivery to the project site.

Item No.	Description of Work	Unit	Qty.	Delivered, Weeks/Months
	DIRECT COST			The project shall be completed within a period of four (4) months from the date of receipt of the Notice to Proceed (NTP)
	Supply and Installation of Triplex Vertical			
	Pressure-Type Depth Filtration System			
A.	General Requirements	lot	1	
	(Mobilization/Demobilization			
B.	Site Works and Civil Works (Excavation,	lot	1	
	Concrete Pads, Drainage)			
C.	Mechanical Works (Delivery and Installation of Filtration System)	lot	1	
D.	Electrical Works (Interfacing and Power	lot	1	
	Connection)			
E.	Plumbing Works (Piping, Fittings, and	lot	1	
	Accessories)			
F.	Testing and Commissioning	lot	1	
G.	Training and Turnover (operator Training	lot	1	
	And Manuals)			
H.	Documentation and As-Built Plans	lot	1	
I.	Health and Safety (PPE, Barricades, Signage)	lot	1	
J.	Contingency	lot	1	
	GRAND TOTAL			



**REVISION NO. 2 - BID DATA SHEET**

FROM		TO	
10.2	1. Latest income and business tax returns filed and paid through the BIR electronic Filing and Payment System (eFPS) 2. Certification coming from the owner of the completed contracts as to the performance of the awarded bidder.	10.2	<i>1. Latest income and business tax returns filed and paid through the BIR electronic Filing and Payment System (eFPS)</i>

**REVISION NO. 3 - BID DATA SHEET**


FROM		TO	
21.2	<p>[List here any additional contract documents relevant to the Project that may be required by existing laws and/or the Procuring Entity.]</p> <p>1. General Condition of the contract duly signed by the bidder. 2. Special Condition of the contract duly signed by the bidder 3. Sample Sales Invoice 4. BIR Form 2303 (Certificate of Registration) 5. The entire filter system must be certified to the following International standards: a. NSF/ANSI 61 b. NSF/ANSI 372 c. CSA 483.1 d. UL/CUL e. CE</p>	21.2	<p>[List here any additional contract documents relevant to the Project that may be required by existing laws and/or the Procuring Entity.]</p> <p>1. General Condition of the contract duly signed by the bidder. 2. Special Condition of the contract duly signed by the bidder 3. Sample Sales Invoice 4. BIR Form 2303 (Certificate of Registration) 5. Certification coming from the owner of the completed contracts as to the performance of the awarded bidder. 6. The entire filter system must be certified to the following International standards: a. NSF/ANSI 61 b. NSF/ANSI 372 c. CSA 483.1 d. UL/CUL e. CE</p>

**SEE ATTACHED THE RESULT OF LATEST PHYSICAL AND CHEMICAL TEST REPORT**

Non-compliance in this Supplemental/Bid Bulletin thereof, may consider the bid as unresponsive to the bidding policies. As a result, this may lead to the disqualification and/or rejection of the prospective bidder’s bid.


This SUPPLEMENTAL/BID BULLETIN, is being issued as clarification to the bidding documents on this 17th day of June 2025.

For the information and guidance of all concerned.

Sgd   
**MARIA LEONORA S. ROMARATE**  
Chairperson-SMWD Bids and Awards Committee







# PLATINUM RESEARCH LABORATORY INC.

SUITE 807, UNION SQUARE CONDOMINIUM 15<sup>TH</sup> AVENUE, CUBAO, QUEZON CITY  
TEL/FAX: 8911-3062/8912-6537/8291-6749 Email: platinumlaboratory@gmail.com

ACCREDITED BY THE DEPARTMENT OF HEALTH  
ACCREDITATION NO.: 13-0004-2224-LW-2

**AB**  
PAB ACCREDITED  
TESTING  
LABORATORY  
PNS ISO/IEC  
17025:2017  
LA-2019-343A

## TEST REPORT

Sample Lab. No. : 22-1037  
Submitted By : Santa Maria Water District  
Address : Santa Maria, Bulacan  
Contact Number : 09192246222  
Sample Source : Deepwell  
Sample Location : Sacred Pump Station (Raw)  
T. Santiago, Poblacion

Date/Time of : 15-Jun-2022  
Collection : 9:35 AM  
Receipt : 15-Jun-2022  
Examination : June 15-30, 2022  
Test Report # PC-2022-1075  
Customer ID #: PRLI-CN#269

WATER QUALITY			
PHYSICAL ANALYSIS			
Parameters	Results	PNSDW Limit	Methodology
Turbidity (NTU)	0.99	5	2130 B. Nephelometric Method
Apparent Color (Color Units)	8	10	2120 B. Visual Comparison
CHEMICAL ANALYSIS			
pH*	9.17	6.5 - 8.5	4500-H+ B. Electrometric
Total Dissolved Solids (mg/L)*	27	600	2540 C. Gravimetric dried at 180°C
Sulfate (mg/L)*	0.1	250	4500-SO <sub>4</sub> <sup>2-</sup> E. Turbidimetric
Nitrate (mg/L)	1.7	50	4500-NO <sub>3</sub> <sup>-</sup> D Electrode Method
Chloride (mg/L)	16	250	4500-Cl- B. Argentometric
METAL ANALYSIS (mg/L)			
Iron (mg/L, total)	0.02	1.00	3111 B. Direct Air-Acetylene
Manganese (mg/L, total)	<0.009	0.40	3111 B. Direct Air-Acetylene
Arsenic (mg/L)	<0.004	0.01	3113 B. Electrothermal AAS
Cadmium (mg/L)	<0.0005	0.003	3113 B. Electrothermal AAS
Lead (mg/L)	<0.002	0.01	3113 B. Electrothermal AAS

odor: with "rotten egg" smell *clm*

### NOTES:

\* ISO/IEC 17025:2017 Accredited Parameters.

**PNSDW** - Philippine National Standards for Drinking Water

*Data italicized are provided by the customer.*

The result apply only to the sample tested by PRLI and shall not be interpreted as approval, disapproval, rejection or endorsement of product from which the sample was obtained. Result(s) of the examination is/are specifically related to sample(s) as received.

### REFERENCES:

American Public Health Association, American Water Works Association, and Water Environment Federation. 2012 Standard Methods for the Examination of Water and Waste Water. 22nd Edition., American Public Health Assoc., Washington D.C.  
Dept. of Health, Philippine National Standards for Drinking Water 2017

Analyzed by:

Sgd  
**Lorraine Mae S. Asaytuno**  
PRC No. 0013916  
Date: July 1, 2022

End of Report

Certified by:

Sgd  
**Harley Joy L. Cruz**  
PRC No. 0009512  
Date: July 1, 2022

THIS REPORT IS NOT VALID WITHOUT DRY SEAL

THIS REPORT CANNOT BE DUPLICATED OR REPRODUCED EXCEPT IN FULL AND SHALL NOT BE USED FOR ADVERTISEMENT OR LITIGATION WITHOUT THE WRITTEN PERMISSION FROM PRLI



Pictures of Water Sample from Pump Station #5:

